Procurement Department Bid Office
Customer Center – 1st Floor, Room 002
21 W. Church Street
Jacksonville, FL 32202

July 2, 2021

ADDENDUM NUMBER: Six (6)

TITLE: Consolidated Rivertown WTP Project Package

JEA IFB NUMBER: 029-21

PROPOSAL DUE DATE: **July 27, 2021**

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 02:00 PM

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

Bids for the Consolidated Rivertown WTP Project were scheduled for opening on 6/8/21; however, JEA received notices from bidders early that day indicating pump suppliers declined to provide bids on pumps due to issues with the specifications without explanation/delineation of the specific pumps or the specific issues. Hence, JEA issued an addendum on 6/8/21 temporarily delaying the opening of bids due to the reported pump specification issues. On 6/11/21, JEA issued a request for detailed explanation of the issues with the pump specifications. On 6/15/21, bidders provided explanations on the issues with the pump specifications. JEA's engineering consultants have reviewed the reported issues with the pump specifications and held technical discussions with the pump suppliers to resolve them. Hence, the following changes will be made to the design documents.

JEA is providing the following documents:

029-21 Addendum 6 – Appendix A Technical Specifications – Volume IV-A – Section 432321.14 Axially Split Case Pumps – High Service Pumps. Remove the original specification and replace with the revised specification Section 432321.14, which is attached to this addendum (Appendix A). Revisions to the specifications are indicated by vertical track-change bars in the margins.

029-21 Addendum 6 Appendix A Technical Specifications – Volume IV-B – Section 44 42 56.03 Vertical Turbine Pump. Remove the original specification and replace with the revised specification Section 44 42 56.03, which is attached to this addendum (Appendix B). Revisions to the specifications are indicated by vertical track-change bars in the margins.

Changes to Specifications:

1. Part 2 Package, Technical Specifications Volume IV-A for the Rivertown Water Treatment Plant Project, Specification Section 333216.13, Paragraph 1.08.B: Delete sentence in its entirety and replace with the following: **"Provide one complete spare submersible grinder pump."**

2. Part 2 Package, Technical Specifications Volume IV-A for the Rivertown Water Treatment Plant Project, Specification Section 400593.23, Paragraph 2.4.E: Delete paragraph in its entirety

Additional Time for Additional Questions:

In consideration of the changes that have been made and the goal of having a good, thorough, and fair Invitation for Bid on this Project, the period for additional questions has been re-opened and will close at **noon on Tuesday, 7/13/21**. Any questions shall be submitted in writing to the Purchasing Agent, David King at kinggd@jea.com.

JEA is extending the bid due date to July 27, 2021

JEA is responding to the following questions as shown below:

1. **Question:**

   I have been asking the GCs but can't get a concise answer, and I hope you can help. Do you need a formal substitution request for the Rivertown WTP project? We are bidding the resinous flooring scope. We've been installing resinous flooring for JEA using our systems on many projects, but I wanted to make sure you didn't need a substitution request for this project. I can always submit our product data sheets with our quote if that would be sufficient.

   Answer:
   Alternate building component or 'or equal' building component products and materials are not reviewed during bidding. An alternate resinous flooring system will only be considered as a substitution request or shop drawing submittal after bid is awarded. We do acknowledge that a resinous flooring system by the supplier (Plexie-Cheme) who asked the question, has been approved and installed on recent JEA projects. Any alternate flooring system must meet the requirements of the specification.